



NATA ACCREDITED Inspection Body

National Association of Testing Authorities, Australia

(ABN 59 004 379 748)

has accredited

**SPP Electrical Pty Ltd
Davidson's Electrical Repair Service**

following demonstration of its technical competence to operate in accordance with

ISO/IEC 17020

As a Type C Inspection Body

This facility is accredited for the inspection activities shown on the
Scope of Accreditation issued by NATA

Jennifer Evans
Chief Executive Officer

Date of issue: 06 June 2017

Date of accreditation: 10 July 2002

Accreditation number: 14828

Scope of Accreditation



ACCREDITATION NO: 14828

SPP Electrical Pty Ltd

Davidson's Electrical Repair Service
5 Featherstone Street
PARKHURST QLD 4702

CONTACT: Mr M Schneider
PHONE: (07) 4936 1733 FAX: (07) 4936 1744 MOBILE:
EMAIL: mark@davidsonselectrical.com.au
WEB SITE: www.davidsonselectrical.com.au

FACILITIES: Type C Inspection Body

This inspection body complies with the requirements of ISO/IEC 17020 (2012)

Industrial equipment and machinery

2.05 Explosion-protected equipment

In-service inspection including overhaul and repair of standard and modified electrical equipment for use in hazardous atmospheres

Codes: AS/NZS 3800 (2012), MP 87.2

ANZEx Certificate of Recognition No. ANZEx SF 12.5828 version 2

Ex 'd' flameproof enclosures

- Flameproof motors and attached flameproof enclosures
- Equipment installed within Ex 'd' enclosures

Ex 'e' increased safety

- Increased safety motors and attached increased safety enclosures
- Equipment installed within Ex 'e' enclosures

Ex 'n' non-sparking

- Non-sparking motors and attached non-sparking enclosures
- Equipment installed within Ex 'n' enclosures

For Group I and Group II equipment

Workshop limitations

- for AC machines 1000 V, 125 A
- incoming power limitation 125 kVA

Accreditation No: 14828

(Scope Last Changed 06/06/17)

**Australian/New Zealand
Recognition Program for**

RECOGNIZED SERVICE FACILITIES

ANZEx Scheme

Certificate No.:	ANZEx SF 12.5828	Issue No.:	2	Date of Issue:	6 June 2017
------------------	-------------------------	------------	----------	----------------	--------------------

Scope of Recognition:

In-service inspection including overhaul and repair of standard and modified electrical equipment for use in hazardous atmospheres

Codes: AS/NZS 3800 (2012)

Ex 'd' flameproof enclosures

- Flameproof motors and attached flameproof enclosures
- Equipment installed within Ex 'd' enclosures

Ex 'e' increased safety

- Increased safety motors and attached increased safety enclosures
- Equipment installed within Ex 'e' enclosures

Ex 'n' non-sparking

- Non-sparking motors and attached non-sparking enclosures
- Equipment installed within Ex 'n' enclosures

For Group I and Group II equipment

Workshop limitations

- for AC machines 1000 V, 125 A
- incoming power limitation 125 kVA

*This certificate is granted subject to the conditions as set out in
Standards Australia/Standards New Zealand Miscellaneous Publication **MP87-2**.*

STANDARDS:

The Service Facility scope and the acceptable variations to it specified in this certificate and the identified documents, was found to comply with the following standards:

AS/NZS 3800 (2012)

FACILITY ASSESSMENT REPORTS:

The facility listed has successfully met the assessment and recognition requirements as recorded in:

File Reference: 14828



**Australian/New Zealand
Recognition Program for**

RECOGNIZED SERVICE FACILITIES

ANZEx Scheme

Certificate No.:	ANZEx SF 12.5828	Issue No.:	2	Date of Issue:	6 June 2017
------------------	-------------------------	------------	----------	----------------	--------------------

Signed for and on behalf of issuing body



Jennifer Evans

CHIEF EXECUTIVE OFFICER

This certificate is not transferable and remains the property of the issuing body
and must be returned in the event of it being revoked or not renewed.

